

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17586

1. OWNER Ray Williams ADDRESS AT WELL LOCATION Yellowdog 1  
 MAILING ADDRESS P.O. Box 111  
Austin Nevada 89310  
 2. LOCATION SW 1/4 NE 1/4 Sec. 7 T 19 N/S R. 44 E Lander County  
 PERMIT NO. 98-600-76 Parcel No. Yellowdog 1 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	18'	18
Granite		18	69'	51
Sands & Gravel	X	69	105	36
Granite + sand streaks	X	105	127	22
Blue Granite		127	160	33
Soft broken Granite	X	160	185	25
Blue Granite		185	200	15

JUL 26 P2:28  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200' Feet Depth Cased 200' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 200' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>1/4"</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation slotted  
 Size perforation 1/8 x 2"  
 From 80' feet to 120' feet  
 From 160' feet to 180' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50' feet to 200' feet

9. WATER LEVEL  
 Static water level 47 feet below land surface  
 Artesian flow NA G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality good

Date started 7-15-91, 19\_\_\_\_  
 Date completed 7-16-91, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>8</u>		<u>4 hrs.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce Young Contractor  
 Address Box 30 M Goldfield Contractor  
Goldfield Nevada  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 871  
 Signed Bruce Young  
 By driller performing actual drilling on site or contractor  
 Date 7-16-91