


OFFICE USE ONLY
Log No. 37186
Permit No. 55145
Basin 04-61


PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16701

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

2. LOCATION NE 1/4 SE 1/4 Sec. 24 T 36 N/S R. 49 E EUREKA County
PERMIT NO. 55145 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAY ROCK AND CLAY		0	195	195
GREEN ROCK & CLAY		195	275	80
BLACK ROCK & CLAY		275	420	145
GRAY ROCK & CLAY		420	470	50
BLACK ROCK AND CLAY		470	505	30
GRAY, WHITE ROCK AND CLAY		505	525	20
BLACK, GRAY ROCK AND CLAY		525	560	35
GRAY ROCK & CLAY		560	635	75
BLACK ROCK FRACT		635	640	5
BLACK ROCK & CLAY		640	715	75
BLACK, GRAY ROCK		715	775	60
BLACK, GRAY ROCK AND CLAY		775	795	20
BLACK, GRAY ROCK		795	815	20
BLACK, GRAY ROCK FRACT		815	880	65
BLACK ROCK & CLAY		880	1000	

Note: Permitter POP SE 1/4 SE 1/4
Special permit terms
OK

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 998 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 23
31 Inches 0 Feet 23 Feet
22 Inches 23 Feet 1000 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	95	.375	0	23
16	63	.375	0	998

Perforations:
Type perforation LOUVERED
Size perforation 1/8"
From 672 feet to 992 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 51 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 51 feet to 1000 feet

Date started JUNE 28TH 1991
Date completed JULY 23RD 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	6'	

9. WATER LEVEL
Static water level 350.36 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 116 °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
Contractor
Address 2286 W. 1500 S.
Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1665

Signed James Titus
By driller performing actual drilling on site or contractor
Date Aug 1, 1991