WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37197
Permit No.
Basin 71

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13818

1. OWNER: Joe Nachiondo
MAILING ADDRESS: 129 W. 6th St, Winnemucca, NV 89445

ADDRESS AT WELL LOCATION: Corner Mary Way & Davey Rd, Winnemucca, NV 89445

2. LOCATION: E½ NE ¼ NE¼ SW ¼ Sec. 7 T. 35 N/S R. 38 E. Humboldt County
PERMIT NO. N/A (Issued by Water Resources) | 10-481-08 (Parcel No.) | Sonoma Ranches Subdivision #1 (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Cemented gravel		8	25	17
Broken rock gravel		25	65	40
Gravel & clay mix		65	172	107
Boulders		172	180	8
Cemented gravel		180	188	8
Bedrock (Dark brown bassalt)		188	200	12

'91 JUL 22 A9:53 STATE ENGINEER'S OFFICE

Date started: July 16, 19 91
Date completed: July 17, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR LIFT	20		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter ..... inches Total depth ..... feet
12 inches 0- 60'
9 7/8 inches 60- 200'

Casing record
Weight per foot ..... Thickness 188

Diameter	From	To
6 inches	0 + 2 feet	150 feet
6 inches	190 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type: Cement Grout
Depth of seal: 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation: Mill Slot
Size perforation: 3 - 32
From 150 feet to 190 Mill Slot feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level: 125 feet below land surface
Flow ..... G.P.M. 20 P.S.I.
Water temperature: Cold °F Quality: Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Humboldt Drilling & Pump Co., Inc. (Contractor)
Address: P.O. Box 592 Wmca., NV 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board: 015234
Nevada contractor's driller's number issued by the Division of Water Resources: 1154
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1533
Signed: [signature] (By driller performing actual drilling on site or contractor)
Date: 7-18-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627