

OFFICE USE ONLY  
 Log No. 37201  
 Permit No. \_\_\_\_\_  
 Basin 85

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17983

1. OWNER ROBERT & JULIE CAMPBELL ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2945 Kietzke Lane 605 Valley Verde  
Reno, NV 89502 Sparks, NV 89436  
 2. LOCATION SE 1/4 SW 1/4 Sec. 20 T. 21N N/S R. 21 E Washoe County  
 PERMIT NO. 076-690-08 Spanish Springs  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
White clay		2	9	7
Red clay		9	11	2
Brown clay		11	41	30
Yellow clay		41	55	14
Brown clay		55	84	29
Yellow clay		84	119	35
Brown clay		119	169	50
Gray clay		169	271	102
Brown clay		271	283	12
Gray clay		283	320	37
Soft zone (NO WATER)		320	322	22
Gray clay		322	381	59
Brown volcanic rock		381	440	59
Gray volcanic rock		440	520	80
Fracture roack	X	520	535	15
Gray volcanic rock		535	550	20

8. WELL CONSTRUCTION  
 Depth Drilled 550 Feet Depth Cased 550 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 550 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	550

 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 445 feet to 465 feet  
 From 485 feet to 505 feet  
 From 525 feet to 545 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 550 feet

Date started 7-23-91, 19\_\_\_\_  
 Date completed 7-26-91, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level 475 feet below land surface  
 Artesian flow 11 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date July 31, 1991