

OFFICE USE ONLY
Log No. 37203
Permit No. _____
Basin 6-87
NOTICE OF INTENT NO. 17319

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Monty Baldwin ADDRESS AT WELL LOCATION 225 Brunswick Mill Rd
MAILING ADDRESS 225 Brunswick Mill Rd 225 Brunswick Mill Rd
Reno, Nv 89511

2. LOCATION NW 1/4 SE 1/4 Sec 11 T 18 N/S R 19 E Washoe County
PERMIT NO. 41-211-03 Parcel No. _____ Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Volcanic sands		296	315	19
Hard rock		315	319	4
Cobbles & volcanic sands		319	322	3
Clay brown		322	329	7
Clay mixed with volcanic rock chips				
multi-colored with scattered cobbles		329	394	65
T.D. 394 ft				

8. WELL CONSTRUCTION
Depth Drilled 394 Feet Depth Cased 394 Feet

HOLE DIAMETER (BIT SIZE)
6 1/8 Inches From 296 Feet To 294 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.66	.188	274	394

Perforations:
Type perforation factory
Size perforation 1/8 X 3
From 354 feet to 374 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal Refer to original log Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc
Contractor
Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
Contractor
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada driller's license number issued by the 1132
Division of Water Resources, the on-site driller.
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date Roger M. Thrall 7/12/91

Date started 7/11/91
Date completed 7/11/91

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>12 - 15</u>		<u>2 1/2</u>