WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37206
Permit No.
Basin 87

NOTICE OF INTENT NO. 17583

1. OWNER THOMAS & GINGER SHEARIN
MAILING ADDRESS 2980 Parkland Drive.
Sparks, NV 89434

ADDRESS AT WELL LOCATION 12350 Westridge
Reno, NV 89511

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 18N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 44-064-08 (Parcel No.) SW Reno off Zollezi Lane (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Boulder		2	4	2
Gravel & sand		4	9	5
Boulder		9	12	3
Brown clay with boulders & gravel		12	90	78
GRanite sands		90	101	11
BRown clay with gravel		101	135	34
GRanite sands	X	135	142	7
BRown sandy clay		142	147	5
Granite sands	X	147	165	8
Large gravels		165	175	10

Date started 7-8-91, 19
Date completed 7-9-91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	175 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	175

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 130 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 175 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1754
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 9, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627