

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 37207  
 Permit No. \_\_\_\_\_  
 Basin. 6-87

I

NOTICE OF INTENT NO. 1756  
 Project # 1669

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

1. OWNER SMITH DETROIT DIESEL ALLISON FACILITY ADDRESS AT WELL LOCATION Project #1669  
 MAILING ADDRESS 8 Glendale Ave Same  
Sparks, NV 89431 MW-3

2. LOCATION SE 1/4 NW 1/4 Sec 9 T 19N N/S R 20 E Washoe County  
 PERMIT NO. M/O#391 ~~391-3~~ 3 Sparks  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty, sandy gravel-brown moist, loose, non-plastic, well graded fill		0	2	2
Clayey, silty sand-brown to gray with red staining, moist, slightly stiff, slightly plastic, well graded		2	5 1/2	3 1/2
Silty sandy gravel-brown, moist, loose non-plastic, well graded		5 1/2	14	9 1/2
Silty clay-reddish brown moist to wet, slightly plastic, poorly graded		14	15	1
Silty sandy gravel-as above, brown with red staining, moist, non-plastic, well graded		15	35	20

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)  
 From 9 Inches To 0 Feet 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"OD		sch 40	0	34

Perforations:  
 Type perforation factory sawed slot  
 Size perforation .020 x 1 1/4" x 3 rows  
 From 14 feet to 33 1/2 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 12ft. w/2 1/2ft bentonite  Neat Cement  
 Placement Method:  Pumped 3 ft  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No w/#3 sand, Lor star  
 From 12 1/2 feet to 35 feet

9. WATER LEVEL  
 Static water level 25 feet below lar \_\_\_\_\_ rface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Address P.O. Box 12370, Reno, NV 89510  
 Contractor

Date started 7-8-91, 19\_\_\_\_  
 Date completed 7-8-91, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Nevada contractor's license number 22549  
 issued by the State Contractor's Board

Nevada driller's license number 908  
 issued by the Division of Water Resources, the/on-site driller.

Signed Wayne Drilling, Inc.  
 by driller performing actual drilling on site or contractor  
 Date October 22, 1991