


Log No. 37210  
 Permit No. 27985  
 Basin. 6-87



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

*PLUGGED BY well log # 11365*

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1723

1. OWNER Pittsburg-Des Moines Steel ADDRESS AT WELL LOCATION 1250 Kleppe Ln  
 MAILING ADDRESS 1250 Kleppe Ln Sparks, Nv 89431

2. LOCATION SW 1/4 SE 1/4 Sec. 10 T. 19 N/S R. 20 E Washoe County  
 PERMIT NO. 27985 34-262-03 Parcel No. - Subdivision Name -  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles & boulders		60	91	31
Mixed clay & cobbles		71	101	30
Green & gray sticky clay with multicolored sand stringers		101	157	56
Gravels & sands		157	179	22
T.D. 179 ft.				
<i>Deeper log # 14620</i>				
'91 AUG 26 P2 04 STATE ENGINEERS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 179 Feet Depth Cased 179 Feet

HOLE DIAMETER (BIT SIZE)  
7 7/8 Inches From 60 Feet To 179 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	50	179

Perforations:  
 Type perforation factory perf  
 Size perforation 3/32 X 3

From 151 feet to 171 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal Refer to original log  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc  
Contractor  
 Address 625 Spice Islands Dr Suite L  
Sparks, Nv 89431  
Contractor

Nevada contractor's license number 15291  
 issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 7/12/91

Date started 7/10/91, 19\_\_\_\_\_  
 Date completed 7/10/91, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>1 hour</u>