WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37215
Permit No.
Basin 092 B Lemmon N.

NOTICE OF INTENT NO. 17992

1. OWNER RANDY & ROBIN ROBINSON
MAILING ADDRESS 7550 Hill View
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ NE ¼ Sec. 10 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources | 88-104-02 Parcel No. | Golden Valley Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING				
Weathered granite		126	138	12
Gray granite		138	186	53
Fracture	X	186	187	1
Gray granite		187	194	7
Fracture	X	194	195	1
Weathered granite		195	204	9
Fracture	X	204	205	1
Weathered granite		205	216	11
FRacture	X	216	217	1
Weathered granite		217	227	10

91 AUG 23 AM 11:26
RECEIVED
STATE ENGINEERS OFFICE

Date started 8-15-91, 19
Date completed 8-16-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 227 Feet Depth Cased 227 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	126 Feet	227 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	227

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 167 feet to 227 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No N/C
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 126 feet to 227 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow 40 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] By driller performing actual drilling on site or contractor
Date August 19, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627