WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39276
Permit No.
Basin 092 - Lemmon V.

NOTICE OF INTENT NO. 17581

1. OWNER: CHRIS DOZIER
MAILING ADDRESS: 3430 Indian Lane, Reno, NV 89506
ADDRESS AT WELL LOCATION: Same

2. LOCATION: NW ¼ SE ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 88-171-03 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Weathered granite		172	182	10
Streak fo white clay		182	183	1
Weathered granite with streaks of white clay		183	240	57
Rusty weatered granite		240	255	15
Soft zone	X	255	270	15
Weaterede granite		270	273	3

'91 AUG 15 AM 10:29 RECEIVED STATE ENGINEER OFFICE

Date started 8-12-91, 19
Date completed 8-12-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 273 Feet Depth Cased 273 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	172 Feet	273 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	273

Perforations:
Type perforation: Factory sawed slot
Size perforation: 3/32 x 3 x 5 around
From 175 feet to 195 feet
From 215 feet to 235 feet
From 255 feet to 273 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No N/A
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 170 feet to 273 feet

9. WATER LEVEL
Static water level 98 feet below land surface
Artesian flow 18 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Wayne Drilling, Inc. (Contractor)
Address: P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board: 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923
Signed: (By driller performing actual drilling on site or contractor)
Date: August 13, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627