

OFFICE USE ONLY
 Log No. 37233
 Permit No. 01-CARSON DESERT
 Basin 01-CARSON DESERT
 NOTICE OF INTENT NO. 17814

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER J & K Llamas ADDRESS AT WELL LOCATION 1021 James Lane
 MAILING ADDRESS 1021 James Lane 1021 James Lane
Fallon, Nevada 89406 Fallon, Nevada 89406
 2. LOCATION NE 1/4 NE 1/4 Sec 35 T 19 N/S R 28 E Churchill County
 PERMIT NO. 54151 17 Taylor Place
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	9	9
Coarse Sand		9	17	8
Brown Clay		17	25	8
Coarse Brown Sand		25	38	13
Sandy Brown Clay		38	42	4
Fine Green Sand		42	51	9
Coarse Green & Black-Sand		51	56	5
Fine Green Sand		56	64	8
Gray Sandy Clay		64	76	12
Coarse Green Black & Brown Sand		76	83	7
Gray Sandy Clay		83	94	11
Black & Brown Coarse Sand		94	98	4
Brown Sandy Clay		98	108	10
Brown Coarse Sand	X	108	120	12

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	0	120

Perforations:
 Type perforation Mill Cut
 Size perforation 178
 From 112 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 120 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Unknown

Date started August 7, 1991
 Date completed August 7, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, Nevada 89406
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
 Signed Douglas N. Parsons
 By driller performing actual drilling on site or contractor
 Date August 9, 1991

91 AUG 15 AM 10:20
 RECEIVED
 STATE ENGINEERS OFFICE