

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19496

1. OWNER Victor Wilson ADDRESS AT WELL LOCATION 3470 Fainky Gardnerville NV 89410
 MAILING ADDRESS 1855 NO. Austin Gardnerville NV 89410
 2. LOCATION SE 1/4 NW 1/4 Sec. 29 T. 10 N/S R. 22 E. Douglas County
 PERMIT NO. 39-080-24 Parcel No. _____ Subdivision Name Topaz Lake

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		165'	180'	
Loose Gravel	X	180'	220'	
Clay & Broken Rock		220'	250'	
Dr. gray clay		250'	270'	
Broken Rock	X	270'	300'	

8. WELL CONSTRUCTION
 Depth Drilled 300' Feet Depth Cased 500' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" Inches 72 Feet To 165' Feet
6 7/8 Inches 145 Feet 300' Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>14</u>	<u>1 3/8</u>	<u>145</u>	<u>300'</u>

 Perforations:
 Type perforation mill slot
 Size perforation 3x 3/32
 From 280 feet to 300' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal _____ Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 9-25, 1991
 Date completed 9-27, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Flow Air</u>	<u>30F</u>		<u>4 Hrs</u>

9. WATER LEVEL
 Static water level 180' feet below land surface
 Artesian flow N/A G.P.M. 30F P.S.I.
 Water temperature cool °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EMDLCO Drilling Contractor
 Address 1443 Hwy 395 South Gardnerville NV 89410 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 24449
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1544
 Signed Martin L. Hadz
 By driller performing actual drilling on site or contractor
 Date 9-27-91

91 OCT 18 P 4:02
 STATE ENGINEERS OFFICE

