WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37245
Permit No.
Basin 137-A

NOTICE OF INTENT NO. 19046

1. OWNER EVERETT E BERG
MAILING ADDRESS FALCON EXPLORATIONS
1900 POWELL STREET EMERYVILLE CA

ADDRESS AT WELL LOCATION BOSS MINE
25 MI. WEST of TONOPAH NV.

2. LOCATION SW ¼ NW ¼ Sec. 31 T. 3N N/S R 39 MDD E ESEMERALDA

PERMIT NO. 51765 (Issued by Water Resources) | Parcel No. | FALCON EXPLORATIONS (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☒ Other CEMENT

4. PROPOSED USE
☐ Domestic MINING ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUT DRILL PIPE				
IN HOLE CEMENTED				
FROM bottom TO Top				
10 SACKS PORTLAND				
NEAT CEMENT				
0-170- CEMENTED				

'91 NOV 25 A11:30
STATE ENGINEERS OFFICE

Date started Sept. 16, 1991
Date completed Sept. 17, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 170' Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	170 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		3/8	0	170

Perforations:
Type perforation SLOT
Size perforation 3/8
From 140 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 2 FT. feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality NOT DRINKABLE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BOYLES BROS DRLG. (Contractor)
Address 975 INDUSTRIAL WY (Contractor)
SPARKS NV. 89431

Nevada contractor's license number issued by the State Contractor's Board 07432

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1332

Signed Chuck Bunning Charles
By driller performing actual drilling on site or contractor

Date Sept. 17, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627