WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37246
Permit No.
Basin 137-A

NOTICE OF INTENT NO. 17753

1. OWNER R. O. Livestock
MAILING ADDRESS Hwy. 376
Round Mtn. Nv 89045

ADDRESS AT WELL LOCATION
Tonopah well site

2. LOCATION SW ¼ SW ¼ Sec. 7 T. 3 N/S R. 42 E Esmeralda County
PERMIT NO. 56266T (Issued by Water Resources) | n/a (Parcel No.) | n/a (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Gravel | | 0 | 25 | 25 |
| Clay | | 25 | 95 | 70 |
| Tan rock | | 95 | 105 | 10 |
| gray clay | | 105 | 170 | 65 |
| Dark green clay | | 170 | 173 | 3 |
| gray clay | | 173 | 265 | 92 |
| green clay | | 265 | 275 | 10 |
| gray clay | | 275 | 295 | 20 |
| gray sandstone w/clay | | 295 | 400 | 105 |

HOLE ABANDONED - NO WATER

backfilled with cuttings 400' to 50' topped with 3/10 yard cement grout

Date started September 11, 1991
Date completed September 11, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 5 3/4 Inches | | 0 Feet | 400 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level ~~n/a~~ Dry feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nv. 89406

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696

Signed Dell Parsons (By driller performing actual drilling on site or contractor)

Date 9-29-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627