

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 37249
 Permit No.
 Basin 6-89
 17320

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO.

1. OWNER Rick & Diane Clemmons ADDRESS AT WELL LOCATION 32 Bellvue
 MAILING ADDRESS 32 Bellvue Parcel B of map 842
 Carson City, Nv 89704
 2. LOCATION NE 1/4 SE 1/4 Sec. 15 T 16 N/S R 19 E Washoe County
 PERMIT NO. SE 55-168-11 - Washoe Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
D. G.		2	8	6
D.G. with brown clay		8	38	30
Medium fine D. G. with pyrite		38	44	6
Mica pyrite granodirite coarse		44	85	41
Green clay with granodirite		85	94	9
Medium fine granodirite brownish color		94	99	5
Gray granodirite medium hard		99	120	21
T.D. 120 ft				

39. 245757° N MAG 27 DO
 119. 827232° W

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 10 Inches From 0 Feet To 120 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		12.92	+ 2	120

Perforations:
 Type perforation screen
 Size perforation .030
 From 100 feet to 110 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 120 feet

Date started 6/28/91 7/1/91, 19
 Date completed 7/2/91, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	20+		4 1/2

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Roger M. Thrall 7/2/91
 Date