WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37281
Permit No.
Basin 91

NOTICE OF INTENT NO. 17582

1. OWNER MIKE & JAMIE POPEJOY
MAILING ADDRESS 430 Magnolia
Reno, NV 89506

ADDRESS AT WELL LOCATION 310 Riverbend
Reno, NV 89523

2. LOCATION SW ¼ SW ¼ Sec. 15 T 19N N/S R 18 E Washoe County

PERMIT NO. (Issued by Water Resources) 038-655-02 (Parcel No.) Beli Ranch Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black top soil		0	3	3
White clay		3	9	6
Sand, coarse		9	13	4
Bolders, gravels, sand		13	69	56
Brown clay with coarse gravels		69	90	21
Gray clay		90	131	41
Soft zone	X	131	132	1
GRay clay		132	209	77
Soft zone	X	209	217	8
Gray clay		217	224	7

'91 JUL 22 A10:00 STATE ENGINEER'S OFFICE

Date started 7-10-91, 19
Date completed 7-12-91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 224 Feet Depth Cased 224 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	224 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	89
5" OD		.188	5	224

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 124 feet to 144 feet
From 164 feet to 184 feet
From 204 feet to 224 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow 18 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date July 17, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627