

OFFICE USE ONLY  
Log No. 37273  
Permit No. \_\_\_\_\_  
Basin 8-103

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17701

1. OWNER DESERT CONSTRUCTION ADDRESS AT WELL LOCATION 2100 N. DEER RUN RD.  
MAILING ADDRESS P.O. Box 1061 CARSON CITY, NV  
DAYTON, NV ACDD  
2. LOCATION SW 1/4 NE 1/4 Sec 11 T 15 N R. 20 E CARSON CITY County  
PERMIT NO. 08-541-35 NONE  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/ GRAVEL		0	43	43
CLAY		43	54	11
SANDY CLAY w/ GRAVEL		54	79	25
FRACTURED DIORITE		79	118	39
SANDY CLAY		118	141	23
SANDY CLAY w/ GRAVEL	✓	141	148	7
SANDY CLAY	✓	148	153	5
SANDY CLAY w/ GRAVEL	✓	153	174	21
SANDY CLAY		174	180	6+

91 JUL 25 P 3:20  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 180 Feet Depth Cased 180 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 100 Feet  
8 3/4 Inches 100 Feet 180 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:  
Type perforation FACTORY SINGLE  
Size perforation 3" x 3/32"  
From 150 feet to 170 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 100'  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 100 feet to 180 feet

9. WATER LEVEL  
Static water level 80 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality GOOD

Date started 7-10, 1991  
Date completed 7-23, 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>7</u>		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EDDCO EXPLORATION, INC Contractor  
Address 7780 CURRY RD. Contractor  
FALLON, NV  
Nevada contractor's license number issued by the State Contractor's Board 27673  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
Signed Pat J. Mooney  
By driller performing actual drilling on site or contractor  
Date 7-24-91