WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37280
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17699

1. OWNER John Bleksen
MAILING ADDRESS P.O. Box 121 Dayton Nv. 89403
ADDRESS AT WELL LOCATION 4050 Northview Carson City Nv.

2. LOCATION SW ¼ SW ¼ Sec. 28 T. 15 N/S R. 20 E. Carson City County
PERMIT NO. (Issued by Water Resources) 10-182-17 (Parcel No.) Cat Ledge (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
Hard Sandstone		15	35	20
Clay Seam		35	40	5
Sandstone		40	65	25
Sandstone w/ small Clay Seams		65	105	40
Clay Seams w/ Small Gravels		105	130	25
Clay Seam		130	155	25
Gravel	XXX	155	170	15
Clay w/ Gravel Seams		170	180	10
T.D. 180'				

Date started July 2, 19 91
Date completed July 5, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
12-15	G.P.M		
Developed w/ Air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4" 60' inches Total depth 180' feet
10" 60 180 inches
inches
Casing record 6 5/8 Steel
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	160' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 180 feet

Perforations:
Type perforation Mill Slot
Size perforation 3/2 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 80' feet below land surface
Flow G.P.M. 10-15 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H.H. Pump Co. (Contractor)
Address 5551 Hy 50 E. C.C. Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-10-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627