

OFFICE USE ONLY
 Log No. 37286
 Permit No. _____
 Basis QAB

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17315

1. OWNER Jim and Jan Batts ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1195 Autumn Hills Dr 4795 North Townsite Rd
Reno, Nv 89511 Lot 3 Block A
 2. LOCATION NE 1/4 NE 1/4 Sec. 11 T. 17 N/S R. 19 E Washoe County
 PERMIT NO. 45-690-09 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	4	4
Cobbles rocks & boulders		4	28	24
Multi colored sands & some brown clay		28	108	80
Cobbles rocks boulders sands		108	128	20
Some cobbles brown clay & coarse multi-colored sands		128	158	30
T.D. 158 ft				

There is a 5 foot blank on the bottom of the perf cellar and development

8. WELL CONSTRUCTION
 Depth Drilled 158 Feet Depth Cased 158 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 158 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1 1/2	158

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 133 feet to 153 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 158 feet

Date started 8/7/91, 19_____
 Date completed 8/8/91, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>45 minutes</u>

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1132
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Roger M. Thrall 8/8/91
 Date _____