

OFFICE USE ONLY
 Log No. 37301
 Permit No. 089
 Basin 089
 NOTICE OF INTENT NO. 14476

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Central Enterprises Inc ADDRESS AT WELL LOCATION 5620 Modras C.C.
 MAILING ADDRESS 790 LaRue Blvd Reno NV
 2. LOCATION SE 1/4 SE 1/4 Sec 14 T. 16 N S R. 19 E Washo County
 PERMIT NO. 055-166-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Sand w/ Seams of Gray Silty Sand Grey</u>		<u>3</u>	<u>65</u>	<u>62</u>
<u>Sand w/ broken D.G.</u>		<u>65</u>	<u>110</u>	<u>45</u>
		<u>110</u>	<u>150</u>	<u>40</u>
<u>T.D. 150'</u>				

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 13/16 Inches 0 Feet 55 Feet
 To 9 7/8 Inches 55 Feet 150 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>188</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Millslot
 Size perforation 3/2 x 3/32
 From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 150 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow Cold G.P.M. 15+ P.S.I.
 Water temperature _____ °F Quality Good

Date started 8-21, 1991
 Date completed 8-23, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15+</u>	<u>50'</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HTA Pump Co Contractor
 Address 5551 N 150 East #3 Carson City NV 89201 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joe Butts
 By driller performing actual drilling on site or contractor
 Date 8-23-91