WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37302
Permit No.
Basin Q89 - WASHOE V.

NOTICE OF INTENT NO. 14457

1. OWNER Richard Mandeville
MAILING ADDRESS P.O Box 2679 Carson City Nv.
ADDRESS AT WELL LOCATION 7595 Old Highway 395

2. LOCATION SW ¼ NE ¼ Sec. 26 T. 16 N/S R. 19 E. Washo County
PERMIT NO. ____ Issued by Water Resources | 005-31-005 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Clay w/ Gravel		4	30	26
D.G (Solid)		30	75	45
Broken DG w/ Lots of Water	XXX	75	100	25
TD 100'				

'91 AUG 27 P2:37 RECEIVED STATE ENGINEER'S OFFICE

Date started 8-15, 1991
Date completed 8-16, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+	80'	2Hr.

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 100'+2 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 3/4 Inches	0 Feet	52 Feet
9 7/8 Inches	52 Feet	100 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+2	100

Perforations:
Type perforation Mill Slot
Size perforation 3/1/2 X 3/32
From 80' feet to 100' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 52'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 52 feet to 100 feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow ____ G.P.M. 35+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+A Pump Co. Contractor
Address 5551 HY 50 East #3 Carson City Nv. Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quinton Butt
By driller performing actual drilling on site or contractor
Date 8-16-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627