WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37309
Permit No.
Basin 091 - TRUCKEE CANYON.

NOTICE OF INTENT NO. 17995

1. OWNER RON FREEMAN
MAILING ADDRESS P.O. Box 69, Verdi, NV 89439
ADDRESS AT WELL LOCATION 605 Deer Mtn. Road, Reno, NV 89523

2. LOCATION SW ¼ SE ¼ Sec. 16 T. 19N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 038-132-23 35 Blue Herron Est. (Beli Ranch) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Cemented boulders & clay		3	5	2
Brown clay		5	18	13
Sandy brown clay		18	60	42
Soft zone		60	79	19
Brown clay		79	91	12
Gray clay		91	131	40
Soft zone	X	131	135	4
Gray clay		135	149	14
Soft zone	X	149	156	7
Gray clay		156	163	7
Dark brown clay		163	175	12

'91 AUG 26 P2:04 STATE ENGINEER

Date started 8-21-91, 19
Date completed 8-22-91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	100 Feet
8 5/8 Inches		100 Feet	175 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	175

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From feet to feet
From 128 feet to 168 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 175 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow 30+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date August 23, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627