

OFFICE USE ONLY
 Log No. 37318
 Permit No. _____
 Basin 102-
 NOTICE OF INTENT NO. 16611

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

1. OWNER Donald A. Szymezak ADDRESS AT WELL LOCATION same
 MAILING ADDRESS 1190 W. 8th St.
Silver Springs, NV 89429
 2. LOCATION NW 1/4 NE 1/4 Sec 13 T. 17 N. R. 25 E. Lyon County
 PERMIT NO. 17-254-16 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil (clay) with gravel, rock		0	3	3
Coarse sand, gravel, rock		3	5	2
Coarse sand, gravel, few rock		5	21	16
Clay, gravel, rock		21	25	4
Coarse sand, gravel, rock		25	35	10
Coarse sand, gravel, few rock		35	47	12
Coarse sand, gravel, clay fill		47	62	15
Coarse sand, gravel, rock		62	70	8
Coarse sand, gravel fill		70	84	14
fractured gray-brown rock		84	90	6
fractured rock w/ clay		90	108	18
fractured gray-brown rock		108	110	2
fractured gray-brown rock, red clay		110	118	8
fractured red rock, red clay		118	135	17
fractured gray-brown rock		135	148' 7/2"	13' 7/2"

8. WELL CONSTRUCTION
 Diameter 10 5/8 inches Total depth 148' 7/2" feet
 Casing record.....
 Weight per foot..... Thickness 1.188
 Diameter From To
6 5/8 inches +1 feet 147' 7/2" feet
 Surface seal: Yes No Type concrete grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 147' 7/2" feet
 Perforations:
 Type perforation sawed
 Size perforation 3/32" x 3" x 6 rows
 From 127' 7/2" feet to 147' 7/2" feet

Date started 8-19, 1991
 Date completed 8-23, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
START CHANGING PITS			
		<u>25:00</u>	<u>26</u>
		<u>02:38</u>	<u>16</u>

9. WATER LEVEL
 Static water level 82 feet below land surface
 Flow..... G.P.M. P.S.I.
 Water temperature cold °F Quality good

BAILER TEST
 G.P.M. 20 Draw down 48 feet 1/2 hour
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Caden Bros Drilling Contractor
 Address 1162 N. Bybee Lane Henderson, NV 89047 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada contractor's driller's number issued by the Division of Water Resources 634
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed [Signature]
 Date 9-23-91