WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37322
Permit No.
Basin 103 - DAYTON V.

NOTICE OF INTENT NO. 16429

1. OWNER Julius Bunkowsky
MAILING ADDRESS Hy 50 East Dayton NV.
ADDRESS AT WELL LOCATION American Flats American Flats Water Co.

2. LOCATION SE ¼ NW ¼ Sec. 7 T. 16 N/S R. 21 E. Storey County
PERMIT NO. 48630 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	15	15
Brown Clay w/ Embeded boulders		15	85	70
Gravel		85	90	5
Clay Brown w/ Gravel Seams	XX	90	175	85
Brown Clay w/ boulders		175	250	75
Boulder w/ Gravel Lots of Water	xxxx	250	295	45

295 T.D.

'91 SEP -5 P3:30 STATE ENGINEERS OFFICE

Date started 8-8, 1991
Date completed 8-15, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	105'	4 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
~~0~~ Inches	~~500~~ Feet	Feet
14¾ Inches	0 Feet	295 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17.09	188	0	295

Perforations:
Type perforation Mill Slot
Size perforation 3½ x 3/32
From feet to feet
From 195' feet to 295' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 58'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 58' feet to 295' feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. 150 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H Pump Co. (Contractor)
Address 5551 Hy 50 East Carson City NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on site driller
Signed Quinton R. Butts (By driller performing actual drilling on site or contractor)
Date 8/26/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627