

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 37329
 Permit No. _____
 Basin 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

23 pack

NOTICE OF INTENT NO. 16126

1. OWNER Jim Henry ADDRESS AT WELL LOCATION 5160 Mallow Rd
 MAILING ADDRESS 2428 E Nye Lane No address assigned as yet
Carson City, Nv 89701 Carson City NV 89701
 2. LOCATION NE 1/4 NE 1/4 Sec 23 T 15 N 20 E Carson City County
 PERMIT NO. 10-087-14 Parcel No. Pinion Hills District Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden & sand		0	15	15
Tight sand w/ gravels		15	60	45
Broken rock, red to red colored		60	105	45
Gravels with minute	xx	105	115	10
Broken and fractured rock with water	xx	115	145	30
TD: 145 ft				
Well static is 110 ft				
Deepening By Well Log 125369				
WELL CAPACITY: 20 GPM				

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 100 Feet
11 3/4 Inches 0 Feet 100 Feet
9 1/2 Inches 100 Feet 145 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	145

Perforations:
 Type perforation Factory Mill Slot
 Size perforation 3/32" x 3"
 From 125 feet to 145 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 145 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature WATER °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO. Contractor
 Address Carson City, NV 89701
5551 Hwy 50 E #3
 Nevada contractor's license number 31839
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 16714
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8/5/91

7. WELL TEST DATA

TEST METHOD:	O.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Blew well and developed with air</u>			
<u>Blowing 20 gpm from 125 feet for 2 hours</u>			