WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 37730
Permit No.
Basin 212

NOTICE OF INTENT NO. 3315

1. OWNER Jerry Ramsey
MAILING ADDRESS 5734 W. Alfred
Las Vegas, Nev. 89108

ADDRESS AT WELL LOCATION
Cougar & ~~Hensen~~ Hinson alg

2. LOCATION NE [redacted] 1/4 [redacted] SE 1/4 Sec. 18 T. 22 N/S R. [redacted] 61 E. Clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt & gravel conglomerate		0	47	47
sand & gravel		47	111	64
cemented conglomerate		111	119	8
sand & gravel		119	190	71
clay sand & gravel		190	305	115
red clay, sand & gravel		305	310	5
gravel	X	310	380	70
partially cemented		380	414	34
gravel conglomerate		414	450	36

RECEIVED
MAY 04 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-16, 19 92
Date completed 4-24, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	?	2

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	450 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1	450

Perforations:
Type perforation Torch
Size perforation 1/8" x 6 x 4 around
From 290 feet to 450 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 240 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View (Contractor)
Las Vegas, Nev. 89103
Nevada contractor's license number issued by the State Contractor's Board 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L. Walk (By driller performing actual drilling on site or contractor)
Date 4-29-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627