

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 37342
 Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 17575

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Little Mondeaux Limousine Ranch ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 74 2901 Jacks Valley Road
Genoa, NV 89411-0400 Genoa, NV 89411-0400
 2. LOCATION NE 1/4 NE 1/4 Sec. 26 T. 14N N/S R. 19 E. Douglas County
 PERMIT NO. M/O #306 LMLR-2 91-072-01 Jacks Valley (N52°07'23"E 770.71 ft)
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam soil		0	3	3
Rock & gravel		3	10	7
Decomposed gravel with sandy loam soil matrix (pockets of silt & clay gray brown color)		10	25	15
Sandy clay lens		25	27	2
Decomposing gravel with clay loam soil matrix (mottung, reddish color)		27	37	10
Clay lens		37	40	3
Gravel with clay soil matrix (gray brown)		40	45	5
Clay lens		45	47.5	2.5
Gravel w/sandy clay soil matrix		47.5	53	5.5
Clay lens		53	55	2
Broken rock		55	56	1
Clay lens		56	59	3
Silty clay loam		59	65	6

8. WELL CONSTRUCTION
 Depth Drilled 65 Feet Depth Cased 64 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8 Inches 0 Feet 65 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" OD		sch 40	2	63.5

Perforations:
 Type perforation factory sawed slot
 Size perforation .020 x 42 slots & 80 slots/row/ft
 From 43.5 feet to 53.5 (42) feet
 From 53.5 feet to 63.5 (80) feet
 From _____ feet to _____ feet
 From End cap & feet to _____ feet
 From Locking Plug feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 2 ft bentonite & 37.5 ft Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No #3 sand
 From 41.5 feet to 64 feet

9. WATER LEVEL
 Static water level 49.7 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality not known

Date started 8-1-91, 19____
 Date completed 8-2-91, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number 908
 issued by the Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date September 12, 1991