

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 16610

PRINT OR TYPE ONLY

1. OWNER Jim Vawter ADDRESS AT WELL LOCATION #2 Nordsyke Rd
 MAILING ADDRESS 21428 Riverview Ct. Yerington, NV 89447
Salinas, CA 93908
 2. LOCATION NE 1/4 NE 1/4 Sec. 21 T. 12 N. S. R. 25 E. Lyon County
 PERMIT NO. 12331-02 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil (clay/sand)		0	5	5
Black coarse sand		5	18	13
Gray coarse sand		18	25	7
Clay		25	30	5
Coarse sand		30	40	10
Coarse sand, gravel		40	73	33
Coarse sand, gravel, rock		73	80	7
Light coarse sand/rock		80	160	80
Loose coarse sand, gravel with few rock	X			

8. WELL CONSTRUCTION

Diameter 12 3/4 inches Total depth 160 feet

Casing record

Weight per foot	Thickness
<u>188</u>	<u>159</u>

Surface seal: Yes No Type concrete grout

Depth of seal 100 feet

Gravel packed: Yes No

Gravel packed from 100 feet to 159 feet

Perforations:

Type perforation sawed

Size perforation 3/32" x 3 x 8 rows

From 139 feet to 159 feet

9. WATER LEVEL

Static water level 12 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature cold °F Quality good

Date started 8-1 1991

Date completed 8-4 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw-Down	After Hours Pump
<u>3600</u>	<u>35</u>	<u>6</u>	<u>2 hrs.</u>
<u>3600</u>	<u>100</u>	<u>11' 6"</u>	<u>2 hrs.</u>

BAILER TEST

G.P.M.	Draw down	feet	hours

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros. Drilling Contractor

Address 162 N. Bybee Lane Yerington, NV 89447 Contractor

Nevada contractor's license number issued by the State Contractor's Board 15646

Nevada contractor's driller's number issued by the Division of Water Resources 634

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed [Signature] By driller performing actual drilling on site or contractor

Date 9-23-91