

OFFICE USE ONLY  
 Log No. 37368  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17458

1. OWNER Charles N. Grant ADDRESS AT WELL LOCATION 1785 Ty. Ln. Gardnerville, Nev. 89410  
 MAILING ADDRESS P.O. Box 2175 Minden, Nev. 89423

2. LOCATION NE 1/4 NW 1/4 Sec. 26 T. 13 N/S R. 20 E E Douglas County  
 PERMIT NO. 23-140-20 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & Clay		0	46	46
Clay, Sticky		46	63	17
Gravel		63	78	15
Clay, Sticky		78	105	27
Gravel & Sand	X	105	152	47
Clay, Gravel Streaks		152	194	42
Gravel	X	194	212	18
Clay		212	228	16
Gravel	X	228	244	16
Clay		244	260	16

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cascd 260 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 260 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		0.188	0	260

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3/32" X 3"  
 From 140 feet to 160 feet  
 From 200 feet to 210 feet  
 From 230 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  Cement Grout  Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 95 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Pre-Cambrian Drilling Co. Inc. Contractor  
 Address 794 Foothill, Rd. Gardnerville, Nev. 89410 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0030267  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 8-6-91

Date started 7/22, 19 91  
 Date completed 7/25, 19 91

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	Not Known	2

'91 AUG 13 AM 1:39  
 STATE ENGINEER'S OFFICE