

OFFICE USE ONLY  
 Log No. 37385  
 Permit No. \_\_\_\_\_  
 Basin 9-108

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16604

1. OWNER Gary Steele ADDRESS AT WELL LOCATION same  
 MAILING ADDRESS 4 Prospect Drive  
Yerington, NV 89447  
 2. LOCATION NE 1/4 NE 1/4 Sec 35 T. 14 N. S. R. 26 E Lyon County  
 PERMIT NO. 04-131-01 Parcel No. Lot #1 Sunny Slope Subdivision Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil - sand, gravel		0	5	5
Coarse sand, gravel, rock		5	15	10
Coarse sand, gravel		15	42	27
Coarse sand, gravel, rock		42	55	13
Coarse sand, gravel		55	84	29
Coarse sand, gravel, clay		84	86	2
Coarse sand, gravel fill		86	104	18
Coarse sand, gravel fill w/ clay		104	156	52
fractured rock, brown clay		156	170	14
Clay, rock		170	182	12
Clay, coarse sand, gravel, rock fill	X	180	200	20
Clay, rock		200	208	8
Clay, coarse sand, gravel		208	216	8
Clay, rock		216	222	6
fractured rock, clay	X	222	264	42

8. WELL CONSTRUCTION  
 Diameter 10 5/8 inches Total depth 264 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 1.188  

Diameter	From	To
<u>6.58</u> inches	<u>+1</u> feet	<u>263</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Concrete grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation sawed  
 Size perforation 3/32" X 3" X 6 rows  
 From 243 feet to 263 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7-1, 1991  
 Date completed 7-10, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<del>_____</del>	<del>_____</del>	<del>_____</del>	<del>_____</del>
<del>_____</del>	<del>_____</del>	<del>_____</del>	<del>_____</del>
<del>_____</del>	<del>_____</del>	<del>_____</del>	<del>_____</del>
<del>_____</del>	<del>_____</del>	<del>_____</del>	<del>_____</del>

BAILER TEST  
 G.P.M. 20 Draw down 20 feet 1/2 hour  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 172' 5" feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros. Drilling Contractor  
 Address 102 N. Bybee Ln. Yerington, NV 89447 Contractor  
 Nevada contractor's license number 15646 issued by the State Contractor's Board  
 Nevada contractor's driller's number 634 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Lois Ogden By driller performing actual drilling on site or contractor  
 Date 9-23-91