

OFFICE USE ONLY
 Log No. 37388
 Permit No. _____
 Basin 129



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17917
Coeur Rochester Mine

1. OWNER COEUR ROCHESTER INC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 1057 _____
Lovelock, NV 89419 _____
 2. LOCATION NE 1/4 SW 1/4 NE 1/4 Sec 15 T 28 Q/S R 34 E Pershing County
 PERMIT NO. M/O 409 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------|--------------|------|-----|-----------|
| Alluvium | | 0 | 30 | 30 |
| Rhyolite | | 30 | 130 | 100 |

Drill 10 inch hole 10 feet deep, then drill on down with 5 1/2 inch bit to 130 feet. Hit water at 80 feet. Installed cap on bottom of slotted pipe and installed 125 feet of blank and 5 feet of .010 inch slotted 2 inch PVC casing in hole, placed 2-100 pound bags of 8 mesh sand around and over slots and finished back filling with 53-50 pound bags of bentonite pellets. Installed 12 feet of 6 inch o.d. steel casing with locking cover in top of hole leaving about a 1 foot stickup.

91 JUL 16 AM 24 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 10 Feet
5 1/2 Inches 10 Feet 130 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 2-3/8 | PVC | Schedule 40 | + .75 | 130 |

Perforations:
 Type perforation slots
 Size perforation .010 inch
 From 125 feet to 130 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 124 feet
 Placement Method: Pumped Poured Bentonite pellets
 Sand
 Gravel Packed: Yes No
 From 124 feet to 130 feet

9. WATER LEVEL
 Static water level 96 feet feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started July 10, 1991
 Date completed July 10, 1991

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| N/A | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HAGWORTH DRILLING, INC. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166
 Signed Dale C. Vidler
 By driller performing actual drilling on site or contractor
 Date 7-15-91