

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18266

1. OWNER Intex Corp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 1440
Long Beach, Ca 90801

2. LOCATION NE 1/4 NE 1/4 Sec. 1 T. 18 N/S R. 20 E Storey County
Sunny Hills Ranchos
 PERMIT NO. _____ Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Volcanic rock mixed with layers of brown clay		0	74	74
More volcanic than clay		74	206	132
Multi-colored volcanic rock with greenish blue sand stone & brown clay		206	272	66
Hard green & black rock		272	278	6
Hard brown clay		278	289	11
Red volcanic rock hard & fractured		289	301	12
Red black white rust volcanic		301	372	71
Rock blue & black		372	462	90
Red-dish volcanic rock		462	517	55
Black & gray rock hard & fractured		517	601	84
Red volcanic rock		601	628	27
Hard black rock		628	637	9
Conglomerant of multi-colored volcanic rock & clays - soft		637	790	153
Black rock with multi-colored clay		790	801	11
Multi-colored soft rock "R Hyolite"		801	818	17

8. WELL CONSTRUCTION
 Depth Drilled 818 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>56</u> Feet
<u>8</u> Inches	<u>56</u> Feet <u>818</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	N/A			

Perforations:
 Type perforation N/A
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 56
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From N/A feet to _____ feet

No water encountered in this bore hole OVER
 Date started 11/8/91, 19____
 Date completed 11/8/91, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>0</u>		<u>1</u>

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431 Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.

Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 11/12/91

Bore filled with native cuttings and grouted
from 56 feet to surface with 5 sack well
grout.

'91 NOV 20 10:54

STATE ENGINEER

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18266

1. OWNER Intex Corp ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P. O. Box 1440
Long Beach, Ca 90801

2. LOCATION NE 1/4 NE 1/4 Sec 1 T 18 N/S R 20 E Storey County _____
PERMIT NO. _____ Subdivision Name Sunny Hills Ranchos
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic rock mixed with layers of brown clay		0	74	74
More volcanic than clay		74	206	132
Multi-colored volcanic rock with greenish blue sand stone & brown clay		206	272	66
Hard green & black rock		272	278	6
Hard brown clay		278	289	11
Red volcanic rock hard & fractured		289	301	12
Red black white rust volcanic		301	372	71
Rock blue & black		372	462	90
Red-dish volcanic rock		462	517	55
Black & gray rock hard & fractured		517	601	84
Red volcanic rock		601	628	27
Hard black rock		628	637	9
Conglomerant of multi-colored volcanic rock & clays - soft		637	790	153
Black rock with multi-colored clay		790	801	11
Multi-colored soft rock "R Hyolite"		801	818	17

8. WELL CONSTRUCTION
Depth Drilled 818 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10	0	56		
8	56	818		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	N/A			

Perforations:
Type perforation N/A
Size perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 56 Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From N/A feet to _____ feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc Contractor
Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431 Contractor
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada driller's license number issued by the 1132
Division of Water Resources, the on-site driller
Signed Rosen thral
By driller performing actual drilling on site or contractor
Date Roger M. Thrall 11/12/91

No water encountered in this bore hole OVER
Date started 11/6/91, 19____
Date completed 11/8/91, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>0</u>		<u>1</u>