WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 3740
Permit No.
Basin 87

NOTICE OF INTENT NO. 18527

1. OWNER Convention Properties LTD.
MAILING ADDRESS P.O. Box 20096
Reno, NV 89515

ADDRESS AT WELL LOCATION 6315 S. McCarran Blvd.
Reno, NV 89509

2. LOCATION ¼ SW ¼ Sec. SE 1 (SECTION 25) T 19N N/S R 19 E Washoe County

PERMIT NO. (Issued by Water Resources) 24-052-58 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On Dec. 20, 1991, we perforated a 6 5/8" well that was 95' deep. Perforations were from bottom to about 18'. We then pumped, using tremie tube, about 1½ yards neat cement from bottom to top. The static water level was 75' from top of well. The casing was then cut off at pump house grade. The well is now abandoned.				

Date started 12-20-'91, 19
Date completed 12-20-'91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719

Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)

Date 12-20-'91

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627