

OFFICE USE ONLY
 Log No. 3747
 Permit No. _____
 Basin. 91

I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20134

1. OWNER NORM ORCUTT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7090 Aspen Glen Road 615 Riverdale Cir.
Reno, NV 89509 Verdi, NV 89439

2. LOCATION NE 1/4 SE 1/4 Sec. 7 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 51694 Lot 4 38-691-02 Riverdale Sub Division
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & sand, some clays		0	37	37
Gray clay		37	42	5
Granite boulder		42	51	9
Gray clay		51	66	15
Volcanic rock		66	86	20
Soft zone (NO WATER)		86	87	1
Gray volcanic rock		87	96	9
Gray clay		96	156	60
Soft zone (NO WATER)		156	157	1
Gray clay		157	164	7
Green clay		164	169	5
Soft zone (app 3 GPM)	X	169	170	1
Green harder clay		170	215	45
Soft zone	X	215	221	6
Green harder clay		221	243	22
Green volcanic rock		243	290	47
Fracture	X	290	297	7
Green volcanic rock		297	310	13
Fracture	X	310	312	2
Green & gray volcanic rock		312	325	13

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10"</u> Inches	<u>0</u> Feet <u>100</u> Feet
<u>8 5/8"</u> Inches	<u>100</u> Feet <u>325</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>325</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around

From	feet to	feet
<u>200</u>	<u>220</u>	feet
<u>240</u>	<u>260</u>	feet
<u>300</u>	<u>320</u>	feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 100 feet to 325 feet

9. WATER LEVEL
 Static water level 99 feet below land surface
 Artesian flow 34 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. Box 12370, Reno, NV 89510

Date started 10-9-91, 19____
 Date completed 10-11-91, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.:	Draw Down (Feet Below Static)	Time (Hours)	

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date October 18, 1991