

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17982

1. OWNER DON BUONAMICI ADDRESS AT WELL LOCATION 3445 Mario Road
 MAILING ADDRESS P.O. Box 2572 Reno, NV 89523
Sparks, NV 89432
 2. LOCATION NE 1/4 NE 1/4 Sec. 22 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 38-681-027 Beli Ranch
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay & gravels some boulders		0	8	8
Brown clay with gravel & larger boulders		8	20	12
Gravels & sand	X	20	28	8
Gray clay		28	45	17
Soft zone		45	46	1
Gray clay		46	93	47
Soft zone		93	94	1
Gray clay		94	111	17
Soft zone	X	111	112	1
Gray clay		112	143	31
Soft zone	X	143	155	12
Gray clay		155	179	24
Soft zone	X	179	180	1
Gray clay		180	200	20

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	32 Feet
10 Inches	32 Feet	100 Feet
8 5/8 Inches	100 Feet	200 Feet

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 115 feet to 125 feet
 From 145 feet to 155 feet
 From 175 feet to 195 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 ft as required Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 200 feet

Date started 9-3-91, 19____
 Date completed 9-6-91, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 9 ft before seal feet below land surface
 Artesian flow 22 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality cleard up well

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
 Date September 12, 1991