WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 31414
Permit No.
Basin 101

NOTICE OF INTENT NO. 18373

1. OWNER JAMES HARMON
MAILING ADDRESS 3280 LONETREE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5230 TOYUEN DRIVE
FALLON, NV 89406

2. LOCATION SE ¼ NW ¼ Sec. 22 T 18 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources 06-433-64 Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	17	17
CLAY		17	21	4
FINE SAND		21	35	14
BLACK CLAY & sand		35	65	30
GRAY CLAY & SAND		65	80	15
GREEN SILT		80	95	15
BROWN CLAY		95	99	4
GRAVEL & COARSE SND X		99	111	12

Date started 08-21-91, 19
Date completed 10-10-91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN @ 45 GPM		

8. WELL CONSTRUCTION
Depth Drilled 111 Feet Depth Cased 111 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 3/4 Inches		50 Feet	111 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	111

Perforations:
Type perforation MACHINE PERF
Size perforation 3/32 X 3
From 104 feet to 109 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 59 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 59 °F Quality UNTSTD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed (By driller performing actual drilling on site or contractor)
Date 10-10-91

STATE ENGINEER'S OFFICE 91 OCT 25 A10:39

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627