WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 3741
Permit No.
Basin 8-10

NOTICE OF INTENT NO. 17768

1. OWNER Mike Casey
MAILING ADDRESS 1600 Allen Road, Fallon, Nev. 89406
ADDRESS AT WELL LOCATION Marshall Road, Fallon, Nev. 89406

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 19 N/S R. 27 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 5 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	33	33
Green Clay		33	46	13
Brown Coarse Sand		46	49	3
Gray Sand		49	57	8
Gray Coarse Sand		57	66	9
Gray Sand		66	80	14
Brown Coarse Sand		80	89	9
Gray Sand		89	91	2
Gray Coarse Sand		91	101	10
Brown Clay		101	104	3
Brown Coarse Sand	X	104	120	16

'91 DEC -2 P12:04
RECEIVED
STATE ENGINEER'S OFFICE

Date started November 16, 19 91
Date completed November 16, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	120

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 114 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 120 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nev. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Nov 25, 1991

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627