WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 31446
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 17553

1. OWNER Jack Cobb
MAILING ADDRESS 2245 Allen Road
Fallon, Nev. 89406

ADDRESS AT WELL LOCATION 3380 Old River Road
Fallon, Nev. 89406

2. LOCATION NW ¼ SW ¼ Sec. 8 T. 19 N/S R. 29 E. Churchill County

PERMIT NO. N/A (Issued by Water Resources) | 17 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TopSoil | | 0 | 8 | 8 |
| Brown Coarse Sand | | 8 | 12 | 4 |
| Brown Clay | | 12 | 14 | 2 |
| Brown Coarse Sand | | 14 | 17 | 3 |
| Green Clay | | 17 | 28 | 11 |
| Black & White Coarse Sand | | 28 | 35 | 7 |
| Green Sand | | 35 | 37 | 2 |
| Black & Green Coarse Sand | | 37 | 45 | 8 |
| Green Sand | | 45 | 57 | 12 |
| Green & Black Coarse Sand | | 57 | 71 | 14 |
| Green Sand | | 71 | 78 | 7 |
| Brown Clay | | 78 | 85 | 7 |
| Brown Coarse Sand | | 85 | 95 | 10 |
| Brown Clay | | 95 | 96 | 1 |

Date started October 24, 19 91
Date completed October 24, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 96 Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 12 | 0 | 96 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 96 |
| | | | | |
| | | | | |

Perforations:
Type perforation MillCut
Size perforation 1/8"
From 92 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 96 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nev. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (Driller performing actual drilling on site or contractor)
Date Oct. 29, 1991

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627