WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37448
Permit No.
Basin 101

NOTICE OF INTENT NO. 19406

1. OWNER MR. + MRS. BOB DOWDLE
MAILING ADDRESS P.O. BOX 11293
TAHOE PARADISE, CA 96155

ADDRESS AT WELL LOCATION
1933 BAFFORD
FALLON, NV

2. LOCATION SE ¼ NE ¼ Sec. 17 T. 19 N S R. 29 E. CHURCHILL County
PERMIT NO. — (Issued by Water Resources) | Parcel No. 07-411-18 | Subdivision Name NONE

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY CLAY | | 0 | 23 | 23 |
| SANDY BOG | ✓ | 23 | 48 | 25 |
| SANDY BLACK CLAY | | 48 | 65 | 17 |
| COARSE SAND | | 65 | 95 | 30 |
| SANDY BLACK CLAY | | 95 | 100 | 5+ |

'91 OCT -8 A10:30
STATE ENGINEER'S OFFICE

Date started 10-3, 1991
Date completed 10-4, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| AIR | 25+ | — | 1 |

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | | 0 Feet | 100 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 17 | .188 | 0 | 100 |

Perforations:
Type perforation FACTORY SINGLE
Size perforation 3" X 3/32"
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patt J. Moon (By driller performing actual drilling on site or contractor)
Date 10-5-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627