WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37461
Permit No.
Basin 41-414

NOTICE OF INTENT NO. 18912

1. OWNER MICHAEL & DANA MCGHEE
MAILING ADDRESS UNIT 162-Box 1
Elko, NV 89801

ADDRESS AT WELL LOCATION NE CORNER OF QUINCY & SOUTH 4th STREET

2. LOCATION NE ¼ SE ¼ Sec. 5 T. 35 0/S R. 57 E. Elko County
PERMIT NO. (Issued by Water Resources) 26-017-05-3 (Parcel No.) TWIN RIVER RANCHO UNIT 5* 4 (Subdivision Name) Lt5 Blk 17

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Gravel (hard)		6	130	124
Sandy clay		130	180	50
Sandstone conglomerate green		180	200	20
Sandstone conglomerate green & orange brown		200	210	10
Sandstone conglomerate broken	x	210	220	10
Sandstone conglomerate gray		220	260	40

'91 NOV -7 A10:37
STATE ENGINEER'S OFFICE

Date started October 26, 1991
Date completed November 5, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Est	7		

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	260 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	260

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 3
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1120
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-6-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627