

OFFICE USE ONLY
 Log No. 37467
 Permit No. _____
 Basin 4-44

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13470

1. OWNER RENNEY BROWN ADDRESS AT WELL LOCATION CORNER OF
 MAILING ADDRESS RYNDEN 265-9 EIGHTH STREET & ARTHUR AVE

2. LOCATION SE 1/4 NW 1/4 Sec. 36 T. 36 N/R 56 E. EIKO County
 PERMIT NO. 06-33H-25-9 Parcel No. _____
 Issued by Water Resources Subdivision Name EIKO RYNDEN

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDSTONE		0	78	78
VOID		78	79	1
CLAY		79	2983	2894
SANDSTONE		83	2891	908
LIMESTONE		181	182	1
SANDSTONE	water	183	192	9
LIMESTONE	water	192	196	4

8. WELL CONSTRUCTION
 Depth Drilled 196 Feet Depth Cased 196 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 196 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.5</u>		<u>1.88</u>	<u>12</u>	<u>-196</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 3"
 From 176 feet to 196 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 6.5' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 6.5 feet to 196 feet

Date started 10-20, 1991
 Date completed 10-25, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>16</u>	<u>50</u>	<u>3</u>

9. WATER LEVEL
 Static water level 124' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fertig Drilling Co Contractor
 Address PO Box 525 EIKO NV 89501 Contractor

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shaul C Fertig
 By driller performing actual drilling on site or contractor
 Date 10-25-91