

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19200

1. OWNER Dew INC ADDRESS AT WELL LOCATION SOUTH OF SEVENTH  
MAILING ADDRESS PO BOX 311 SEVENTH STREET CARROLL CA  
ELKO NV 89501 Grant Ave East side of Grant Ave  
2. LOCATION NE 1/4 SE 1/4 Sec 36 T 36 N 8 R 56 E ELKO County  
PERMIT NO. 06-324-56-0 Parcel No. Ryndon Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	18	18
CLAY		18	52	34
LIMESTONE		52	53	1
CLAY		53	69	15
SANDSTONE		69	84	16
LIMESTONE		84	90	12
LOW LIMESTONE	Water	90	103	

91 NOV 25 11:23  
STATE ENGINEERS

8. WELL CONSTRUCTION  
Depth Drilled 103 Feet Depth Cased 103 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10 Inches 0 Feet 103 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6 3/8 \_\_\_\_\_ 198 23 103  
Perforations:  
Type perforation slots  
Size perforation 3/16 x 3  
From 53 feet to 103 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 55  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 55 feet to 103 feet

9. WATER LEVEL  
Static water level 20 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Fertig Drilling Co Contractor  
Address PO Box 525 ELKO NV 89501 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 31904  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1534  
Signed Sheldon Ferguson  
By driller performing actual drilling on site or contractor  
Date 11-16-91

Date started 11-12, 1991  
Date completed 11-13, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>1 1/2</u>