

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19205

1. OWNER DEW INC ADDRESS AT WELL LOCATION CORNER OF GRANT AVE SEVENTH STREET  
 MAILING ADDRESS PO Box 311 ELKO NV 89501  
 2. LOCATION NE 1/4 SE 1/4 Sec. 36 T. 56 N/S R. 56 E ELKO County  
 PERMIT NO. 06-33M-52-2 Parcel No. Rynday Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Standy loam		0	18	18
SAND		18	23	5
CLAY		23	52	59
LIMESTONE		52	54	2
CLAY		54	99	15
LESS LIMESTONE	water	99	105	6

8. WELL CONSTRUCTION  
 Depth Drilled 105 Feet Depth Cased 105 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
~~10~~ Inches ~~0~~ Feet ~~105~~ Feet  
10 Inches 0 Feet 105 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>		<u>1.88</u>	<u>7.3</u>	<u>105</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/16 - 3  
 From 8.5 feet to 105 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5.5  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 5.5 feet to 105 feet

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.8 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address PO Box 525 ELKO NV 89501 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554  
 Signed Shane Fertig  
 By driller performing actual drilling on site or contractor  
 Date 11-12-91

Date started 11-13 1991  
 Date completed 11-15 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		<u>3</u>