WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37486
Permit No.
Basin 49

NOTICE OF INTENT NO. 17923

1. OWNER Kevin & Diane Wilkinson
MAILING ADDRESS Osino Box 292-13
Elko, NV 89801

ADDRESS AT WELL LOCATION SE corner of south third & Seneca Avenue

2. LOCATION NW ¼ NE ¼ Sec. 9 T. 35 N/S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) 35-037-04-3 (Parcel No.) Lot 4 Blk 37 Meadow Valley Ranchos Unit 3 (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 3 | 3 |
| Siltstone | | 3 | 160 | 157 |
| Sandy clay | | 160 | 200 | 40 |
| Siltstone | | 200 | 260 | 60 |
| Sand & gravel | | 260 | 320 | 60 |

Date started September 11, 19 91
Date completed September 18, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Est | 10 | | |

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10-5/8 Inches | | 0 Feet | 320 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1½ | 320 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 299 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [x] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 125 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Darce Hersh (By driller performing actual drilling on site or contractor)
Date 9-26-1991

RECEIVED 91 OCT 28 P 1:05 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627