WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37492
Permit No.
Basin 50

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13913

1. OWNER VAN WATERS & ROGERS
MAILING ADDRESS BOX 310
Carlin, NV 89822

ADDRESS AT WELL LOCATION None
3 mi East of Carlin, NV

2. LOCATION SE ¼ SW ¼ Sec. 19 T. 33 N S R. 53 E. Elko County
PERMIT NO. 43062 (Issued by Water Resources) Parcel No. NONE (Subdivision Name)

3. TYPE OF WORK Abandon
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| A new well was drilled to replace this well because of the poor quality of water from this well. This well was approx. 122 ft. deep. The casing in this well was broken @ 22 ft & approx. 15 gpm was entering the well through the break. When the new well was cemented to 100 ft. the cement came through the formation into this well, cementing it back to 82 ft. 82 ft of tremie line was inserted into this well & pumped full through the tremie line back to the surface. After setting overnight the casing was cut off 4 ft. below ground surface. | | | | |

Date started 10-15, 1991
Date completed 10-15, 1991

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter inches Total depth feet
inches
inches
Casing record 8 5/8 steel
Weight per foot Thickness .250

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

WELL DRILLERS REPORT

9. WATER LEVEL
Static water level feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality POOR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING CO. (Contractor Drilling Co.)
Address 203 PINE ST. (Contractor Street) Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada contractor's driller's number issued by the Division of Water Resources 632
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed (By driller performing actual drilling on site or contractor)
Date 10-20-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627