WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37497
Permit No.
Basin 61

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16725

1. OWNER Newmont Gold Company
MAILING ADDRESS P.O. Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION
GQP-22

2. LOCATION NW ¼ NE ¼ Sec. 2 T. 33 N/S R. 51 E. Eureka County
PERMIT NO. M/O 246-B (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Monitor
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown limestone		0	70	70
Sand & silt	x	70	120	50
Sandstone		120	200	80
Brown silty sand	x	200	235	35
Clay		235	290	55
Silt & sand	x	290	300	10
Sand & clay		300	355	55
Gray & brown sand		355	365	10
Sand		365	485	120
Silty clay		485	500	15
Gray sand		500	530	30
Brown clay		530	625	95
Gray sand & clay		625	675	50
Sand & green clay		675	710	35
Cement plug from 710' to 350'				
N 40.782556 W 116.204491 NAD27 mined off and Plugged under NOI 59820				

Date started 9-20, 19 91
Date completed 9-25, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter ..... inches Total depth 350 feet
14" 0-52 inches
8" 52 - 132 inches
Casing record Steel 2" PVC
Weight per foot 14" 37#; 8" 23# Thickness Sch. 80

Diameter	From	To	
10 inches	+1 feet	52 feet	
8 inches	+3 feet	132 feet	
inches	feet	feet	
2 inches	+3 feet	225 feet	Solid
2 inches	235 feet	245 feet	
inches	feet	feet	

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 225 feet to 235 feet

Perforations:
Type perforation Slotted 2" PVC
Size perforation 0.10
From 225 feet to 235 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 85 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elsing Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 919; Twin Falls, ID 83303-0919 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0017177
Nevada contractor's driller's number issued by the Division of Water Resources 1295
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 945
Signed Arnold Elsing (By driller performing actual drilling on site or contractor)
Date 9-25-91

91 SEP 27 P12:55

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627