


**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety



NOTICE OF PERMIT NO. 20317

PRINT OR TYPE ONLY

1. OWNER Newmont Gold Company ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 669 \_\_\_\_\_  
Carlin, NV 89822 \_\_\_\_\_  
 2. LOCATION SW  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 29 T. 34 N S R. 52 E Eureka County  
 PERMIT NO. M/O 184-H Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. Monitor PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	5	5
Gravel		5	12	7
Sandy clay		12	85	73
Sandy clay & gravel	x	85	106	21
Siltstone		106	235	129
Sandy clay	x	235	261	26
5' Monument				

91 DEC -2 11:20 AM  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 261 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record Steel 1 1/2" PVC  
 Weight per foot .250 17# Thickness Sch. 80  

Diameter	From	To
<u>6</u> inches	<u>+3</u> feet	<u>2</u> feet
_____ inches	_____ feet	_____ feet
<u>1 1/2</u> inches	<u>+2</u> feet	<u>260</u> feet
<u>1 1/2</u> inches	<u>+2</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 230 feet to 260 feet  
140 feet to 160 feet  
 Perforations:  
 Type perforation Slotted 1 1/2" PVC  
 Size perforation 0.10  
 From 260 feet to 230 feet  
 From 160 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Dual

Date started 11-7 1991  
 Date completed 11-8 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Elsing Drilling & Pump Co., Inc.  
 Contractor  
 Address P.O. Box 919; Twin Falls, ID 83303-0919  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0017177  
 Nevada contractor's driller's number issued by the Division of Water Resources 1295  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 945  
 Signed Arnold Elsing  
 By driller performing actual drilling on site or contractor  
 Date November 26, 1991