WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37567
Permit No.
Basin 70

NOTICE OF INTENT NO. 17936

1. OWNER David Lorain
MAILING ADDRESS 3040 Valley Way Wmca., Nv. 89445
ADDRESS AT WELL LOCATION 7190 Cloud Burst

2. LOCATION SW ¼ SE ¼ Sec. 14 T. 35 N N/S R. 37 E E. Humboldt County
PERMIT NO. (Issued by Water Resources) 1333104 (Parcel No.) Block A Lot # 3 Thomas Canyon Estates (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[x] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Brown		0	1	1
Hard Clay Brown		1	4	3
Sandy Clay Brown		4	79	75
Gravel Brown		79	84	5
Gravely Clay Brown		84	96	12
Clay with strips of				
Sand + Gravel Brown	24	96	120	

Date started 10-22-91, 19
Date completed 11-1-91, 19

7. WELL TEST DATA
TEST METHOD: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	4	2½

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	.188	0	120

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T + R DRILLING (Contractor)
Address P.O. Box 1982 Wmca., Nv. 89446 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas (By driller performing actual drilling on site or contractor)
Date 11-5-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627