WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37568
Permit No.
Basin 70

NOTICE OF INTENT NO. 15460

1. OWNER Brad Santucci
MAILING ADDRESS 6860 W. Rosecreek
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 6860 W. Rosecreek
Winnemucca, NV 89445

2. LOCATION NE ¼ NW ¼ Sec 16 T 35 N/S R 37 E Humboldt County
PERMIT NO. N/A Issued by Water Resources
6860 W. Rosecreek Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Soil		0	28	28
Gravel		28	67	39
Clay, Some Gravel		67	84	17
Clay		84	97	13
Gravel	X	97	132	35
Clay/Gravel Mix		132	160	28
Gravel	X	160	190	30
Clay		190	205	15
Clay/Gravel Mix	X	205	215	10
Clay		215	252	37

Date started September 20, 19 91
Date completed September 20, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	180'	4

8. WELL CONSTRUCTION
Depth Drilled 252 Feet Depth Cased 252 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches	0 Feet	252 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.02	.250	+2	132
6 5/8	17.02	.250	172	192
6 5/8	17.02	.250	232	252

Perforations:
Type perforation Perf Mill
Size perforation 1/8 x 2
From 132 feet to 172 feet
From 192 feet to 232 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 252 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. Contractor
Address P.O. Box 590 Contractor
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-18-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627