WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37594
Permit No.
Basin 72

NOTICE OF INTENT NO. 15458

1. OWNER Frank Olagary
MAILING ADDRESS P.O. Box 13401
Sansuis Obisto, Cal 93406

ADDRESS AT WELL LOCATION Star Route Box 49
10 mi So. 1st Ranch
Union, NV

2. LOCATION NE ¼ SE ¼ Sec. 4 T. 31 N/S R. 47 E. Pershing County

PERMIT NO. N/A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt & gravel		0	12	12
Gravel		12	22	10
Clay & gravel		22	28	6
Cobbles & gravel		28	52	24
Gravel		52	160	108
Big cobbles ground		160	255	95

91 SEP 12 AM 8:52
STATE ENGINEER

Date started SEptember 7, 19 91
Date completed September 10, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	Air on rig	

8. WELL CONSTRUCTION
Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	255 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	195
6 5/8	12.92	.188	235	255

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 2
From 195 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 255 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. (Contractor)
Address P.O. Box 592 Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed C. O. Eyler (By driller performing actual drilling on site or contractor)
Date 9-11-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627